

CMS Sustainability Subcommittee - 8/25 SD recommendations

Option #	Request to the Design Team	Subcommittee Recommendation
1	Further investigate a hybrid natural ventilation strategy (beyond opening windows).	Not Recommended
2	Further investigate a complete displacement ventilation system.	Not Recommended
3	Present options for a partial displacement ventilation system.	Recommended
4	Present options for a dehumidification only system (no air conditioning).	Not Recommended
5	Further investigate a partial air conditioning system - heat pump sizing based on heating demand, which is lower than the air condition peak, so there would be no air conditioning at the extreme.	Not Recommended
	Reduce the number of EV charging stations from the requirements listed in the EZ-Code to 2% installed	
6	spaces connected to building (meet LEED goal).	Recommended
7	Allow mechanicals systems to be placed on the roof.	Recommended
8	Target EV charging infrastructure for 10% of parking as EV ready.	Recommended